

DECLARATION OF COMPLIANCE

Puricom Europe S.L.
C/ Aiguafreda, 8
Pol. Ind. L´Ametlla Park
08480 – L´Ametlla del Vallès (Barcelona)

WE DECLARE under our own responsibility that:

THE WATER TREATMENT UNITS BY REVERSE OSMOSIS TECHNOLOGY, WITH BRAND NAME "RO PROLINE PLUS" BELONGING TO THE RANGE OF PRODUCTS CALLED **RO8.S**, INCLUDING A REMINERALIZER POSTFILTER,

Meet the criteria and test cases under established by:
THE UNE 149101 STANDARD, WATER TREATMENT EQUIPMENT INSIDE BUILDINGS. FITNESS BASIC CRITERIA USED IN WATER TREATMENT FOR HUMAN CONSUMPTION INSIDE BUILDINGS.

Water quality dispensed, testing and sweep organic compounds.

It hasn't been detected any compound in the migration test by GC-MS after an extraction water-water with dichloromethane according to standard BS EN 15768 GC-MS.

*In particular, **there hasn't been detected traces of Bisphenol A** in the sample tested.*

*The model RO8.S.1, representative of the **RO8.S PRODUCT RANGE**, dispenses water which **MEETS** migration of polymer materials required by **Regulation UE 10/2011 and RD 847/2011***

*All parameters analyzed from water samples of the migration assay are within the limits established by **Royal Decree 140/2003 and European Drinking Water Directive 98/83 CE**.*

*The model RO8.S.1, representative of the **RO8.S PRODUCT RANGE**, tested **which MEETS with the provisions in the tables 2, 3, 4, and 5 and the Annex B of the standard UNE 149101.***

RO8.S.1 WATER TREATMENT UNIT, REPRESENTATIVE OF THE **RO8.S** RANGE OF PRODUCTS,

was tested by the laboratory:

STENCO

C/ GRAN VIAL 5, EN MONTORNÉS DEL VALLÉS (BARCELONE. SPAIN).
WWW.STENCO.ES

Name and position of the authorized person:
Signature, place and date:

José Antonio Fogued Franco – Manager
L´Ametlla del Vallès, Barcelone, Spain

06/05/2016

